

# Product Safety Recall

Kubota Australia Pty Ltd – Kubota Generators – Various Models

**Models:**

- DA5500E, DW160E
- GL6000, GL9000
- J108, J112, J130
- KJ-T130DX, KJ-T80VX, KJ-T230FX
- RKA150E



**Defect:** The generators are not fitted with overcurrent protection that acts in all live conductors and all socket outlets do not have individual switching of all live conductors.

**Hazard:** Risk of electric shock causing serious injury or death.

**What should consumers do:** Stop using the Generator. Contact the Authorised Kubota Dealer where you purchased your equipment to arrange for inspection and maintenance.

- You may also go to <https://kubota.com.au/dealers> and search by postcode and selecting “Generators” as the Product Range and search for your closest dealer.
- You can also visit the Kubota Generator campaign web site at <https://kubota.com.au/service/safety-recalls> where you can search your serial number and model.

For more information contact Kubota on 1300 582 582

See [productsafety.gov.au](https://productsafety.gov.au) for  
Australian product recall information